

Clean Environment, Safe Water

Korea Environment & Water Works Institute

86-3 6Ga, Yangpyeong-Dong, Youngdeungpo-Gu, Seoul, Korea /TEL 82-2-2637-1234 /FAX 82-2-2631-8767

Report Of Laboratory Tests

* Representative : HEE JONG, YOON

* Date Of Receipt : Aug. 20, 2003

* Name(Company) : . INC.

* Issue Date : Sep. 1, 2003

* Address : WANG-DONG, SHI HEUNG-CITY, KYUNGGI-DO, KOREA

* Analysis Date : Aug. 20 - Sep. 1

* Commodity : AIR-WATER

Items	Drinking Water Standard		Result	Items	Drinking water Standard		Result
	Conc.	Unit			Conc.	Unit	
1. Pb	below 0.05	mg/L	ND	19. Trichloroethylene	below 0.05	mg/L	ND
2. F	below 1.5	mg/L	ND	20. Dichloromethane	below 0.02	mg/L	ND
3. As	below 0.05	mg/L	ND	21. Benzene	below 0.01	mg/L	ND
4. Se	below 0.01	mg/L	ND	22. Toluene	below 0.7	mg/L	ND
5. Hg	below 0.001	mg/L	ND	23. Ethylbenzene	below 0.3	mg/L	ND
6. CN	below 0.01	mg/L	ND	24. Xylene	below 0.5	mg/L	ND
7. Cr ⁶⁺	below 0.05	mg/L	ND	25. 1,1-Dichloroethylene	below 0.05	mg/L	ND
8. NH ₃ -N	below 0.5	mg/L	ND	26. Carbon tetrachloride	below 0.002	mg/L	ND
9. NO ₃ -N	below 10	mg/L	ND	27. 1,2-Dibromo-3-chloropropane	below 0.008	mg/L	ND
10. Cd	below 0.005	mg/L	ND	28. Free residual chlorine	below 4.0	mg/L	ND
11. Boron	below 0.3	mg/L	ND	29. Trihalomethanes	below 0.1	mg/L	ND
12. Phenol	below 0.005	mg/L	ND	30. Chloroform	below 0.08	mg/L	ND
13. Diazinon	below 0.02	mg/L	ND	31. Chloralhydrate	below 0.03	mg/L	ND
14. Parathion	below 0.06	mg/L	ND	32. Dibromoacetonitril	below 0.1	mg/L	ND
15. Fenitrothion	below 0.04	mg/L	ND	33. Dichloroacetonitril	below 0.09	mg/L	ND
16. Carbaryl	below 0.07	mg/L	ND	34. Trichloroacetonitril	below 0.004	mg/L	ND
17. 1,1,1-Trichloroethane	below 0.1	mg/L	ND	35. Haloacetic acids	below 0.1	mg/L	ND
18. Tetrachloroethylene	below 0.01	mg/L	ND				

* Purpose : Reference

* Experimental method : Korea Standard Test Method for Drinking water

* ND : Not Detected

* Don'T Rewrite This Report Without Written Admission.

Korea Environment & Water Works Institute

